

**Compliance Schedule Details:**

**SS 15/1 – Systems for Communicating Spoken Information to Facilitate Evacuation**

Please provide the following information with your Building Consent Application - Form 2

(If you need help to complete this form, consult the system provider or an IQP who is registered for the system above)

Applicant Name: .....	Building Name: .....
Site Address: .....	Installation provider: (if known) .....
.....	.....
Existing Compliance Schedule Number(s): (if applicable) .....	Risk / Purpose group: .....
.....	Fire Hazard Category: .....
.....	Total Occupant Load: .....

**SPECIFIED SYSTEM DESCRIPTION** (address those items that apply)

<b>Specified systems:</b>	<input type="checkbox"/> Existing <input type="checkbox"/> New <input type="checkbox"/> Modified <input type="checkbox"/> Removed
<b>Type:</b>	<input type="checkbox"/> A building intercom system for use by the Fire Service <input type="checkbox"/> A public address system to facilitate staged evacuation <input type="checkbox"/> An emergency warning intercommunications system (EWIS) <input type="checkbox"/> Other: [specify] .....

Location Plan for specified systems and records is attached:  YES  NO

No.	Equipment location	Make (Main components)	Model
1			
2			
3			
4			

*If needed continue the list on another sheet of paper*

**STANDARDS** (address those items that apply)

Specifically designed solutions do not apply if the system has been installed against a specific Standard(s) / document.

<p>Performance / installation</p>	<ul style="list-style-type: none"> <li><input type="checkbox"/> AS 2220:1989 Emergency warning and intercommunication systems in buildings Part 1: 1989 Equipment design and manufacture Part 2: 1989 System design, installation and commissioning</li> <li><input type="checkbox"/> AS 2220.1-1989/Amdt 2-1993 Emergency warning and intercommunication systems in buildings</li> <li><input type="checkbox"/> AS 1851-2012/Amdt 1-2016 Routine service of fire protection systems and equipment</li> <li><input type="checkbox"/> AS 1851-2012 Routine service of fire protection systems and equipment</li> <li><input type="checkbox"/> AS 1851:2005 Maintenance of Fire Protection Systems and Equipment</li> <li><input type="checkbox"/> NZS 4512:2020 Fire detection and alarm systems in buildings.</li> <li><input type="checkbox"/> NZS 4512:2010 Fire detection and alarm systems in buildings.</li> <li><input type="checkbox"/> NZS 4512:2003 Fire detection and alarm systems in buildings.</li> <li><input type="checkbox"/> NZS 4512:1997 Fire alarm systems in buildings.</li> <li><input type="checkbox"/> NZS 4512:1994 Fire alarm systems in buildings.</li> <li><input type="checkbox"/> NZS 4512:1981 Automatic fire alarm systems in buildings.</li> <li><input type="checkbox"/> NZS 4561:1973 Specification for manual fire alarm systems.</li> <li><input type="checkbox"/> NZS 2211:1968 Manual fire alarm systems for use in buildings.</li> <li><input type="checkbox"/> Other: .....</li> <li><input type="checkbox"/> Specifically, designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so. (Details provided)</li> </ul>
<p>Inspections</p>	<ul style="list-style-type: none"> <li><input type="checkbox"/> NZS 4512:2010 – Part 6</li> <li><input type="checkbox"/> NZS 4512:2003 – Part 6</li> <li><input type="checkbox"/> NZS 4512:1997 – Part 6</li> <li><input type="checkbox"/> NZS 4512:1994 – Part 6</li> <li><input type="checkbox"/> NZS 4512:1981 – Part 6</li> <li><input type="checkbox"/> Other: .....</li> <li><input type="checkbox"/> Specifically, designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so. (Details provided)</li> </ul>

Maintenance	<input type="checkbox"/> NZS 4512:2010 – Part 6 <input type="checkbox"/> NZS 4512:2003 – Part 6 <input type="checkbox"/> NZS 4512:1997 – Part 6 <input type="checkbox"/> NZS 4512:1994 – Part 6 <input type="checkbox"/> NZS 4512:1981 – Part 6 <input type="checkbox"/> Other: .....	<input type="checkbox"/> Specifically, designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so. (Details provided)	<i>Continue on next page</i>
<b>INSPECTIONS, MAINTENANCE AND REPORTING</b> (address those items that apply)			
<b>Minimum inspection and maintenance procedures:</b>	Regular inspection and testing and planned preventative maintenance and responsive maintenance will be carried out in accordance with the nominated performance and inspection Standard/document, and to ensure the system will operate as required in the event of a fire.		
<b>Inspection frequency and responsibility:</b>	Depending on the type of installation and its performance standard/document: <input type="checkbox"/> Specifically, designed solutions: by IQP only <input type="checkbox"/> Standard /other document: <input type="checkbox"/> Monthly: by IQP only <input type="checkbox"/> Annually: by IQP only		