

**Compliance Schedule Details: SS 5 – Escape Route Pressurisation Systems**

Please provide the following information with your Building Consent Application - Form 2  
 (If you need help to complete this form, consult the system provider or an IQP who is registered for the system above)

Applicant Name: .....	Building Name: .....
Site Address: .....	Installation provider: (if known) .....
Existing Compliance Schedule Number(s): (if applicable) .....	Risk / Purpose group: .....
.....	Fire Hazard Category: .....
.....	Total Occupant Load: .....

**SPECIFIED SYSTEM DESCRIPTION** (address those items that apply)

<b>Specified systems are:</b>	<input type="checkbox"/> Existing <input type="checkbox"/> New <input type="checkbox"/> Modified <input type="checkbox"/> Removed
<b>Type:</b>	<input type="checkbox"/> Corridor pressurisation system <input type="checkbox"/> Stairwell pressurisation system

**Location Plan for specified systems and records is attached:**  YES  NO

No.	Equipment location	Make (Main components)	Model
1			
2			
3			
4			

*If needed continue the list on another sheet of paper*

**STANDARDS** (address those items that apply)

Specifically, designed solutions do not apply if the system has been installed against a specific Standard(s)/document.

<b>Performance / installation:</b>	<input type="checkbox"/> AS/NZS 1668:1:2015 The use of ventilation and air-conditioning in buildings. Part 1: Fire and smoke control in buildings <input type="checkbox"/> AS/NZS 1668:1998 The use of ventilation and air-conditioning in buildings Part 1: Fire and smoke control in multi-compartment buildings <input type="checkbox"/> Specifically, designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so. (Details provided) <input type="checkbox"/> Other: .....
<b>Inspections:</b>	<input type="checkbox"/> AS 1851:2012 <input type="checkbox"/> Specifically, designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so. (Details provided) <input type="checkbox"/> AS1851:2005 <input type="checkbox"/> Other: .....
<b>Maintenance:</b>	<input type="checkbox"/> AS 1851:2012 <input type="checkbox"/> Specifically, designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so. (Details provided) <input type="checkbox"/> AS1851:2005 <input type="checkbox"/> Other: .....

**INSPECTIONS, MAINTENANCE AND REPORTING** (address those items that apply)

<b>Minimum inspection and maintenance procedures:</b>	Regular inspection and testing and planned preventative maintenance and responsive maintenance will be carried out in accordance with the nominated performance and inspection standard or document to ensure the system will operate as required in the event of a fire. <i>Continue on the next page</i>
---	---

<b>Inspection frequency and responsibility:</b>	Depending on the type of installation and its performance standard/document: <input type="checkbox"/> Specifically, designed solutions: by IQP only <input type="checkbox"/> Standard /other document: AS 1851 by IQP only
<b>Reporting:</b>	The owner will keep records of all inspections, maintenance and repairs undertaken in the previous 24 months. These will be recorded in the On-Site Log Book, which will remain on the premises with the most recent compliance schedule, and as a minimum include: <ul style="list-style-type: none"><li>• Details of any inspection, test or preventative maintenance carried out, including dates, works undertaken, faults found, remedies applied and the person who performed the work.</li><li>• Form 12A provided annually by the IQP</li></ul>